



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 3, 2008

**Re:** Guernsey County  
Seneca Lake Camp Lagoons  
Compliance Schedule Violations  
NPDES Permit #0PX00002\*AD  
Correspondence (PWW)

Mr. Boris Slogar, Chief Engineer  
Muskingum Watershed Conservancy District  
1319 Third Street  
New Philadelphia, Ohio 44663

Dear Mr. Slogar:

A recent NOV letter was sent to your agency asking for an explanation of the past discharge monitoring report violations for the Seneca Lake Lagoon's wastewater treatment plant from July through December. Our office has yet to receive an explanation as to why these violations occurred and actions which will be taken to prevent further occurrences.

The final effluent limit of .011 mg/l will also become effective on May 1, 2008 and effluent violations will likely occur as there is no current effective means of de-chlorination. A PTI was approved in May 2007 for the installation of a new chlorination and de-chlorination system which will be necessary to meet the final effluent limits. Please provide a schedule within **10** days upon receipt as to when the new disinfection system will be installed as well as a response to the NOV letter dated February 19, 2008. Failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Jeffrey Lacheta, Muskingum Watershed Conservancy District