



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 5, 2007

Re: Guernsey County
Quaker City WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PA00003*GD
Correspondence (PWW)

Mayor and Council
Village of Quaker City
210 Smith Avenue, P.O. Box 156
Quaker City, Ohio 43773

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of July through August 2007 for the Quaker City wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Conc	30	44.	8/15/2007
001	00530	Total Suspended Solids	7D Qty	9	17.4867	8/15/2007

* 7D Conc is equal to a weekly average concentration limit.
1D Conc is equal to the minimum daily concentration limit.
30D Conc is equal to a monthly average concentration limit.

The July MOR reported a fecal coliform sample as "AK", which is a violation of your permit. Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Eric Phillips, Operator, Envirotech Environmental