



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

April 13, 2007

**Re:** Guernsey County  
Village of Quaker City  
Self-Monitoring Report Violations  
Ohio EPA Permit No. OPA00003\*GD  
Correspondence (PWW)

Mayor and Council  
Village of Quaker City  
210 Smith Avenue  
P.O. Box 156  
Quaker City, Ohio 43773

Dear Mayor and Council:

We have received your self-monitoring reports covering the month of February 2007 for the village wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Conc.	45	57.	2/1/2007

\*7 D Conc. is equal to average weekly concentration limit.

Please submit within 10 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. Our review also indicates that multiple weekly samples were not collected within the seven day weekly periods as defined in your permit. Please ensure future weekly samples are collected within the defined 7-day weekly period according to the definition in your permit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Eric Phillips, Operator, Envirotech Environmental