



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

February 7, 2007

**Re: Guernsey County  
Quaker City WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit No.0PA00003\*GD  
Correspondence (PWW)**

Mayor and Council  
Village of Quaker City  
210 Smith Avenue  
P.O. Box 61  
Quaker City, Ohio 43773

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of October through December 2006 for the Quaker City wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Qty	9	20.5336	10/15/2006
001	00530	Total Suspended Solids	30D Qty	6	6.34745	10/1/2006
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.25	7.13	10/8/2006
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.7	1.26839	10/8/2006
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	3.9195	10/1/2006
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.5	.68518	10/1/2006
001	80082	CBOD 5 day	7D Qty	6	9.0348	10/15/2006

- \*7 D Conc is equal to average weekly concentration limit.
- 7 D Qty is equal to average weekly loading limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to average monthly loading limit.

According to Part I, C of your permit the village was also to submit an I&I control plan which contains items 1 through 4, with item 3 omitted. An I&I control plan was received by Mr. Eric Phillips on January 9, 2007 although upon review was found to be insufficient. An updated plan should be submitted including a map of the collection area and identification of known problem areas. An investigative schedule should be developed to prioritize those areas upstream of sewer system backups or overflows. The control plan should describe how the collection system and manholes will be tested, proposed budget and list of potential funding sources, and an implementation schedule to reduce identified sources.

Please submit **within 45 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. In addition, please submit an updated I&I control plan as described above with a 2006 annual report for I&I control measures completed this past year. The continued failure to produce an acceptable I&I control plan and lack of effort from the village to reduce I&I flows will lead to future enforcement actions.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/mlm

c. Eric Phillips, Operator, Envirotec Environmental Engineering



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 7, 2007

**Re:** Guernsey County  
Village of Pleasant City WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit No.0PB00088\*AD  
Correspondence (PWW)

Mayor and Council  
Village of Pleasant City  
P.O. Box 272  
Pleasant City, Ohio 43772

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of October through November 2006 for the Pleasant City's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	6.54489	11/1/2006
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	5.42	11/8/2006
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	16.05	11/15/2006
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	7.623	11/22/2006

\*7 D Conc is equal to average weekly concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please submit **within 10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/mlm