



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kortleski, Director

January 5, 2009

**Re: Guernsey County
Langley-Lew Mobile Home Park
Self-Monitoring Report Violations
NPDES Permit #0PV00524*AD
Correspondence (PWW)**

Mr. Willie Langley
819 Lakeside Drive
Cambridge, Ohio 43725

Dear Mr. Langley:

We have reviewed your self-monitoring reports covering the months of October through November 2008 for the Langley-Lew MHP, formerly known as the Pine View MHP. Our review indicates a November MOR was not submitted, as well as other violations to your NPDES permit. Monthly reports are required to be submitted by the 15th of the month for the preceding month's data if filed by hardcopy and if using the web based eDMR program by the 20th. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	40.	10/1/2008
001	00530	Total Suspended Solids	7D Conc	18	40.	10/1/2008
001	00530	Total Suspended Solids	30D Qty	0.14	.36336	10/1/2008
001	00530	Total Suspended Solids	7D Qty	0.20	.36336	10/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	16.1	10/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.3	16.1	10/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.017	.14625	10/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.026	.14625	10/1/2008
001	31616	Fecal Coliform	30D Conc	1000	10158.6	10/1/2008
001	31616	Fecal Coliform	7D Conc	2000	4200.	10/1/2008
001	80082	CBOD 5 day	30D Conc	10	160.	10/1/2008
001	80082	CBOD 5 day	7D Conc	15	160.	10/1/2008
001	80082	CBOD 5 day	30D Qty	0.11	1.45344	10/1/2008
001	80082	CBOD 5 day	7D Qty	0.17	1.45344	10/1/2008
001	31616	Fecal Coliform	7D Conc	2000	24571.	10/15/2008
001	00300	Dissolved Oxygen	1D Conc	5.0	1.5	10/16/2008

* 1 D Conc is equal to the maximum daily concentration limit.
7D Conc is equal to the average weekly concentration limit.
7D Qty is equal to the average weekly loading limit.
30D Conc is equal to the average monthly concentration limit.
30D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

In my last violation letter sent earlier this month I asked you to provide actions you were taking to minimize flow to the plant by eliminating connections. Please provide an update on the progress to eliminate some existing connections since the current plant is not adequate to provide treatment at the current waste flows without major improvements. Failure to significantly reduce the flow to the wastewater treatment plant and take immediate operational actions to achieve permit compliance will require significant upgrades to the plant to maintain compliance. The failure to submit the necessary engineering plans to achieve permit compliance is a direct violation of the compliance schedule in your permit. If you have plans of continuing the operation of the mobile home park immediate actions shall be taken to improve the treatment plant.

A permit renewal application was recently received for this facility to begin the renewal process. Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. A monthly report for November shall also be submitted to our Columbus office.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Guernsey County Health Department