



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 5, 2007

**Re: Guernsey County**  
Lake Seneca Resorts WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PX00003\*DD  
Correspondence (PWW)

Lake Seneca Resorts Association  
c/o Lake Seneca Resorts Trustees  
17875 Lashley Road  
Senecaville, Ohio 43780

Dear Trustees:

We have received your self-monitoring reports covering the months of July through August 2007 for the Lake Seneca Resorts wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:


Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.50	4.065	7/1/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.25	6.02	7/1/2007
001	00300	Dissolved Oxygen	1D Conc	6.0	5.	7/4/2007
001	80082	CBOD 5 day	7D Conc	12	16.	7/8/2007
001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	7/17/2007
<b>August 2007:</b>						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.50	2.94333	8/1/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.25	8.6	8/1/2007
001	31616	Fecal Coliform	30D Conc	1000	3529.87	8/1/2007
001	31616	Fecal Coliform	7D Conc	2000	8900.	8/1/2007

\* 7D Conc is equal to a weekly average concentration limit.  
1D Conc is equal to the minimum daily concentration limit.  
30D Conc is equal to a monthly average concentration limit.

Please submit within **10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. Upon review of the July MOR it was also found that a fecal coliform sample was reported as "AK" on July 4, 2007, please provide an explanation for this high concentration as well.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator