



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 7, 2008

Re: Guernsey County
Eastern Alliance Living Facility
Self-Monitoring Report Violations
Ohio EPA Permit No.0PP00085*BD
Correspondence (PWW)

Mr. Rod Hollingsworth
Eastern Alliance Council of Governments
1205 Newark Road
Zanesville, Ohio 43701

Dear Mr. Hollingsworth:

We have received your self-monitoring reports covering the months of August through September 2008 for the Eastern Alliance Living Facility. Our review indicates frequency violations were committed as the following pollutants were not analyzed in September. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	1/Month	1	0	09/01/2008
001	00610	Nitrogen, Ammonia (NH3)	1/Month	1	0	09/01/2008
001	31616	Fecal Coliform	1/Month	1	0	09/01/2008
001	80082	CBOD 5 day	1/Month	1	0	09/01/2008
001	50060	Chlorine, Total Residual	1/2Weeks	1	0	09/01/2008
001	50060	Chlorine, Total Residual	1/2Weeks	1	0	09/15/2008

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Michael Wisecarver, Operator, Wisecarver Environmental