



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 5, 2007

**Re:** Guernsey County  
Coventry Estates II Subdivision WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. OPG00043\*ED  
Correspondence (PWW)

Guernsey County Board of Commissioners  
627 Wheeling Avenue  
Suite 300  
Cambridge, Ohio 43725-2251

Dear Board of Commissioners:

We have received your self-monitoring reports covering the months of March through April 2007 for the Coventry Estates II Subdivision's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Conc	18	33.	3/15/2007
001	00530	Total Suspended Solids	7D Qty	2.04	2.22331	3/15/2007


\*7D Conc is equal to a weekly average concentration limit.  
7D Qty is equal to the weekly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

- c: Dennis Dougherty, Operator, Guernsey Co. Water and Sewer Department
- c: Clarence Ridgley, Superintendent, Guernsey Co. Water and Sewer Department