



State of Ohio Environmental Protection Agency

Southeast District Office

21 95 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 24, 2007

Re: Guernsey County
Village of Byesville
NOV (0PB00004, OH0024287)
Correspondence (PWW)

Mayor and Council
Village of Byesville
221 East Main Street
P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of October 2005 through August 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
November 2005:					
001	Average	Suspended Solids	60.4	kg/day	56.8
001	Week 3	Suspended Solids	134	kg/day	85.2
January 2006:					
001	Weeks 1&3	Suspended Solids	92.6-212	kg/day	85.2
001	Average	Suspended Solids	103	kg/day	56.8
March 2006:					
001	3/1	Oil and Grease	11	mg/l	10
May 2006:					
001	Week 3	Suspended Solids	117	kg/day	85.2
001	5/17	Chlorine Residual	0.06	mg/l	0.038
July 2006:					
001	Weeks 1&2	Suspended Solids	86.2-104	kg/day	85.2
001	Average	Suspended Solids	62.6	kg/day	56.8
August 2006:					
001	8/14	pH	5.9	S.U.	6.5 Minimum
September 2006:					
001	9/18	Chlorine Residual	0.51	mg/l	0.038
001	Week 1	Fecal Coliform	"AK"	#/100ml	2000
October 2006:					
001	Week 3	Suspended Solids	131	kg/day	85.2
001	Average	Suspended Solids	77.6	kg/day	56.8
November 2006:					
001	Average	Suspended Solids	57.3	Kg/day	56.8
January 2007:					
001	Week 3	Suspended Solids	96.1	Kg/day	85.2


Outfall	Date	Parameter	Reported	Units	Permit Limitation
February 2007:					
001	Weeks 3&4	Suspended Solids	96.3-99.0	Kg/day	85.2
001	Average	Suspended Solids	78.7	Kg/day	56.8
001	2 Days	pH	9.6-9.8	S.U.	9.0 maximum
March 2007:					
001	Average	Suspended Solids	117	Kg/day	56.8
001	Weeks 3&4	Suspended Solids	125-169	Kg/day	85.2
April 2007:					
001	Average	Suspended Solids	46	Mg/l	30
001	Average	Suspended Solids	68.8	Kg/day	56.8
001	Week 2	Suspended Solids	80	Mg/l	45
001	Weeks 1&2	Suspended Solids	95.3-99.3	Kg/day	85.2

We have reviewed your reports addressing the aforementioned violations. No additional information is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer - Environmental Specialist 2
Division of Surface Water

JMW/dh

Enclosure