



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 15, 2007

**Re: Guemsey County
Buffalo Subway
Self-Monitoring Report Violations
Ohio EPA Permit No.0PR00098*AD
Correspondence (PWW)**

Mr. Paul Queen
Subway, Buffalo Restaurant
92 Wexford Drive
Granville, Ohio 43023

Dear Mr. Queen:

We have received your self-monitoring reports covering the month of December 2006 for the Buffalo Subway Store. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00300	Dissolved Oxygen	1D Conc	5.0	3.25	12/4/2006
001	00300	Dissolved Oxygen	1D Conc	5.0	2.6	12/18/2006
001	00530	Total Suspended Solids	1D Conc	18	26.	12/18/2006
001	00530	Total Suspended Solids	30D Conc	12	21.	12/1/2006
001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	18.7	12/4/2006
001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	16.5	12/18/2006
001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	17.6	12/1/2006
001	80082	CBOD 5 day	1D Conc	15	41.	12/4/2006
001	80082	CBOD 5 day	1D Conc	15	38.	12/18/2006
001	80082	CBOD 5 day	30D Conc	10	39.5	12/1/2006

*1 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/mlm