



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 5, 2007

Re: Guernsey County
Beech Meadows Subdivision WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPG00018*HD
Correspondence (PWW)

Guernsey County Board of Commissioners
627 Wheeling Avenue
Suite 300
Cambridge, Ohio 43725-2251

Dear Board of Commissioners:

We have received your self-monitoring reports covering the months of March through April 2007 for the Beech Meadows Subdivision's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	30D Conc	10	19.75	3/1/2007
001	80082	CBOD 5 day	30D Qty	1.52	2.15291	3/1/2007
001	80082	CBOD 5 day	7D Conc	15	79.	3/8/2007
001	80082	CBOD 5 day	7D Qty	2.27	8.61163	3/8/2007


*7D Conc is equal to a weekly average concentration limit.
7D Qty is equal to the weekly loading limit.
30 D Conc is equal to average monthly concentration limit.
30 D Qty is equal to monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

- c: Dennis Dougherty, Operator, Guernsey Co. Water & Sewer Department
- c: Clarence Ridgley, Supt., Guernsey Co. Water & Sewer Department