



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 19, 2008

**Re: Guernsey County
Byesville Water Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 0IY00100*BD
Correspondence (IWW)**

Mayor and Council
Village of Byesville
221 East Main Street, P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of April through July 2008 for the Byesville water treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	4/4/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	4/8/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	4/9/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	4/14/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	4/15/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.12	4/18/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.11	4/19/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.11	4/22/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.12	4/25/2008
May 2008:						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	5/5/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	5/7/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	5/8/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	5/14/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	5/15/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.11	5/19/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.29	5/21/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	5/22/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.12	5/27/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	5/28/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	5/31/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	6/1/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.12	6/4/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	6/6/2008

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	6/9/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	6/10/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	6/11/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	6/16/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	6/18/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	6/21/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	6/28/2008
July 2008:						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	7/3/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	7/7/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	7/9/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	7/10/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	7/17/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	7/18/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	7/21/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	7/24/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	7/25/2008

*1 D Conc is equal to the maximum daily concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111. These residual chlorine violations have been reported for seven consecutive months and have placed your facility on our significant non-compliance list, which subject you to enforcement action. A site inspection was conducted with Mr. McVickers several months ago at which time several suggestions were made to assist with chlorine removal. Please provide written documentation of the completion of these measures as well as the status of rebuilding the filter beds which are deficient of adequate filter sand.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
 District Representative
 Division of Surface Water

JJG/dh

c: Thomas McVicker, Superintendent