



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 13, 2009

**Re: Guernsey County
Langley-Lew MHP
Compliance Inspection
Correspondence (PWW)**

Mr. Willie Langley
Langley-Lew Mobile Home Park
819 Lakeside Drive
Cambridge, Ohio 43725

Dear Mr. Langley:

A recent inspection of your facility conducted a few weeks ago found most of the mobile home units to have been vacated or removed from your mobile home park with only a couple remaining. As requested in an inspection completed in February, you were asked to remove tenants from the park and cap the discharge from your treatment plant. During my recent inspection, I found the blower unit to have been disconnected from the aeration tank although a discharge was still occurring. In order to prevent a further discharge, the outlet pipe from the aeration tank shall be capped and encapsulated with concrete. In the interim until the final couple tenants vacate the premise the tank can be used as a holding tank. Upon removal of all tenants, all piping should be removed; tanks punctured and then filled with clean hard fill.

Please complete these measures to eliminate the discharge within **30 days** upon receipt of this letter. Upon receipt of this documentation, a No Permit Required (NPR) form will be completed and your current NPDES permit will be rescinded.

If you have any questions, please call me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

Enclosure

c: Guernsey County Health Department