



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 21, 2009

Re: Guernsey County
Shenandoah Travel Plaza
Correspondence (PWW)

Mr. Ron Myers, CEO
Shenandoah Travel Plaza
P.O. Box 147
State Route 285
Old Washington, Ohio 43768

Dear Mr. Myers:

On April 9, 2009, I received a written response from Matt Stiers, contract operator, regarding the wastewater treatment plant deficiencies noted in my March 24, 2009 compliance inspection letter. The response letter stated that three estimates to make the necessary repairs to the clarifier tanks were recently received. The significant leak between the two clarifier tanks has been observed since the plant went back on line and a request to get it repaired has been made multiple times. Currently, neither clarifier is in operation although the facility has been discharging partially treated wastewater for several months. Part III, Item 3 of your NPDES discharge permit requires that all treatment systems of your plant to be maintained and in full working order. The current bypassing of your clarifier due to the severe leak is a direct violation of Part III, Item 3 and failure to make immediate repairs may result in formal enforcement action. A written response shall be received within **7 days** upon receipt of this letter stating how the necessary repairs will be made to the clarifier tanks within **30 days**.

If you have any questions please call me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

Enclosure

c: Andy Luburgh, Owner
c: Matt Stiers, Operator
c: Guernsey County Health Department