



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 26, 2007

**Re: Guernsey County
Secret Elementary WWTP
Reconnaissance Inspection
Correspondence (PWW)**

Mr. Gary Norris, Superintendent
Rolling Hills School District
P.O. Box 38
Byesville, Ohio 43723

Dear Mr. Norris:

On October 11, 2007, I conducted a reconnaissance inspection at the Secret Elementary School's wastewater treatment plant. The purpose of the inspection was to determine if any work has begun to repair the chlorination system and install the new dechlorination chamber. Mr. Matt Stiers, plant operator was present at the time of my inspection.

Based on the findings of my inspection and the review of our records, I have the following comments:

1. The plant currently has no effective means to properly disinfect the treated wastewater due to the absence of a chlorination and dechlorination chamber. A PTI was approved for the installation of a dechlorination chamber which should be installed within **30** days upon receipt of this letter. All necessary repairs to the existing chlorination contact tank should also be completed within the same time frame.
2. Wastewater flow should be diverted to the clean filter bed so the other bed can dry to facilitate cleaning and removal of the solids.

Please submit documentation within **30** days upon receipt of this letter verifying installation of the new disinfection units. Attached is a copy of my detailed inspection report for your review.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JGG/dh

Enclosure

c: Matt Stiers, Operator

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00010*AD	OH0091375	October 11, 2007	R	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Secrest Elementary WWTP Township Road 4581 Senecaville, Ohio	12:15 p.m.	July 1, 2004
	Exit Time	Permit Expiration Date
	12:30 p.m.	June 30, 2009

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Matt Stiers, Operator	(740) 685-6776
Name, Address and Title of Responsible Official	Phone Number
Gary Norris, Superintendent Rolling Hills School District P.O. Box 38 Byesville, Ohio 43723	


C. AREAS EVALUATED DURING INSPECTION

- | | | |
|-----------------------------------|------------------------------------|----------------------------------|
| <u>S</u> Permit | <u>--</u> Flow Measurement | <u>--</u> Pretreatment |
| <u>S</u> Records/Reports | <u>--</u> Laboratory | <u>U</u> Compliance Schedules |
| <u>M</u> Operations & Maintenance | <u>S</u> Effluent/Receiving Waters | <u>S</u> Self-Monitoring Program |
| <u>S</u> Facility Site Review | <u>--</u> Sludge Storage/Disposal | <u> </u> Other |
| <u>--</u> Collection System | | |

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See attached letter.



 Jake Greney, Inspector, Ohio EPA, Southeast District Office

10/29/07

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

10/29/07

 Date