



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 5, 2010

Re: Muskingum County
Philo Middle School
CEI
Permit #OPT00044*CD
Correspondence (PWW)

Mr. Robert Walden, Assistant Supt.
Franklin Local School District
Philo Middle School
360 Cedar Street
Duncan Falls, Ohio 43734

Subject: Compliance Evaluation Inspection

Dear Mr. Walden:

On March 22, 2010, I conducted a Compliance Evaluation Inspection at the Philo Middle School WWTP. I was accompanied by George Spears, operator of the facility.

I found no apparent violations at the time of the inspection.

If you have any questions or comments, please feel free to call at (740) 380-5227.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00044*CD	OH0124753	March 22, 2010	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Philo Middle School 225 Market Street Philo, Ohio 43771	1:20 PM	April 1, 2008
	Exit Time	Permit Expiration Date
	2:00 PM	March 31, 2013

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
George Spears, Operator	740-704-2022
Name, Address and Title of Responsible Official	Phone Number
Robert Walden, Assistant Superintendent Franklin Local School District 360 Cedar Street Duncan Falls, Ohio 43734	740-674-5203


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>N/A</u> Other
<u>N/A</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See attached letter.



 Scott Foster, Inspector, Ohio EPA, Southeast District Office

4/5/10

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

4/5/10

 Date