



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 25, 2007

Re: Muskingum County
West Muskingum Subdivision WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPG00012*HD
NPDES Permit No. OH0050440
Correspondence (PWW)

Mr. Jeffrey Pickrell, Utilities Director
Muskingum County Sewers
1410 Newark Road
P.O. Box 2819
Zanesville, Ohio 43701

Dear Mr. Pickrell:

We have received your self-monitoring report covering the month of February 2007, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Permit No.	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.1	11.3725	02/01/07
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.26	.94881	02/01/07
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	8.0	8.11	02/13/07
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	8.0	12.	02/20/07
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.98	.9947	02/20/07
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	8.0	15.6	02/23/07
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.98	1.58243	02/23/07
OPG00012*HD	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	8.0	9.78	02/27/07


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh