



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 14, 2008

Re: Muskingum County
Roseville WTP
2009 CEI
Correspondence (IWW)

Mr. Paul Mills, Operator of Record
Village of Roseville WTP
459 Gordon Street
Roseville, Ohio 43777

Dear Mr. Mills:

On September 18, 2008, I conducted a compliance evaluation inspection at the Roseville water treatment plant. I conducted the inspection to check the village's compliance with its NPDES permit. I was accompanied on the inspection with Dan Messerly, Ohio EPA; Randy Bruce, Laborer, Roseville; Bryan Hina, Laborer, Roseville and Jeff Slack, Village Administrator, Roseville.

The sludge ponds were full and staff informed me that sludge had been removed in July of 2008. The sludge pump was broke again and the belt press had not been operated in quite awhile.

The records for the year 2008 were not available at the time of the inspection. The plant appeared to be in disrepair.


On October 2, 2008, Tim Campbell, Ohio EPA and I met with Kim Dixon, Mayor of Roseville and Jeff Slack, Village Administrator of Roseville. We spoke about sludge removal for the treatment plant and the general overall condition of the facility. After the meeting we toured the facility and had found a vast improvement from the previous inspection of two weeks before.

On October 3, 2008, the Ohio EPA informed Mr. Slack that the village could use the 360 acres of strip mine land the village owns for disposal of their lime sludge. The village is going to forward pictures of the lime sludge disposal to the Ohio EPA for their files. The Ohio EPA has also been in contact with the Operator of Record, Paul Mills, and have been informed of sludge being hauled from the facility. A copy of the inspection report is attached.

Roseville WTP
Page 2

If you have any additional questions or comments, please feel free to call me at (740)
380-5227.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Foster", with a long horizontal flourish extending to the right.

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

c: Kim Dixon, Mayor, Village of Roseville
c: Jeff Slack, Village of Roseville

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IW00122*DD	OH0031496	September 18, 2008	C	S	2

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Roseville Water Treatment Plant 459 Gordon Street Roseville, Ohio 43777	9:00 a.m.	August 1, 2006
	Exit Time	Permit Expiration Date
	9:30 a.m.	July 31, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Paul Mills, Operator of Record	740-704-9115
Name, Address and Title of Responsible Official	Phone Number
Kim Dixon, Mayor Village of Roseville 107 North Main Street Roseville, Ohio 43777	(740) 697-0322


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>N</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>S</u> Compliance Schedules
<u>M</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>M</u> Sludge Storage/Disposal	<u>N</u> Other
<u>N</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See Attached Letter.



Scott Foster, Inspector, Ohio EPA, Southeast District Office

10/14/08

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

10/14/08

Date