



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

August 9, 2007

Re: Muskingum County
Longaberger Company
Reconnaissance Inspection
Correspondence (IWW)

Mr. Todd Fitz, Director of Legal Relations
The Longaberger Company
P.O. Box 3400
Newark, Ohio 43058-3400

Dear Mr. Fitz:

On July 19, 2007, Tim Campbell, Southeast District, Ohio EPA, Division of Surface Water, and I conducted a Reconnaissance Inspection for the Longaberger WWTP. The operator was not present. The following are comments from the inspection:

The new curtain has been installed in the Biolac tank. However, before Ms. Robinson's departure, Longaberger had been working with URS Consultants for replacement of the current wastewater system. Please provide an update on the progress of this project.

There is a large amount of duckweed on the settling tank. It appears that the skimmer is not working properly.

The air diffuser was leaking at the surface and appeared to be damaged.

The plant was in disarray. There are lots of weeds growing, old parts lying on the ground, and it reflects a lack of maintenance.

Please respond to this letter by August 30, 2007.

If you have any comments or questions, please feel free to call me at (740) 380-5227.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
01M00018*DD	OH0107786	July 19, 2007	R	S	2

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Longaberger Co Plant 1 WWTP 5565 Raiders Road Frazeytsburg, Ohio 43822	8:30 AM	April 1, 2006
	Exit Time	Permit Expiration Date
	8:45 AM	March 31, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Maryann Figgins, Operator	740-627-6406
Name, Address and Title of Responsible Official	Phone Number
Todd Fitz, Director of Legal Affairs PO Box 3400 Newark, Ohio 43058-3400	740-322-5356


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>S</u> Compliance Schedules
<u>M</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>N</u> Facility Site Review	<u>M</u> Sludge Storage/Disposal	<u>--</u> Other
<u>N</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See Attached Letter.



Scott Foster, Inspector, Ohio EPA, Southeast District Office

8/9/07

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

8/9/07

Date