



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 24, 2007

**Re: Muskingum County
Carl Rittberger Sr., Inc.
CEI - Permit #01H00003*CD
Correspondence (IWW)**

Mr. Andrew Rittberger, President
Carl Rittberger Sr., Inc.
1900 Lutz Lane
Zanesville, Ohio 43701

Subject: Compliance Evaluation Inspection, please respond by June 15, 2007

Dear Mr. Rittberger:

On May 15, 2007, Tim Campbell and I conducted a compliance Evaluation Inspection at your facility. We were accompanied by Kevin Norris, Rittberger Maintenance and yourself. The following are comments from the inspection:

➤ **The flow meter is past due for calibration:**

The calibration sticker on the flow meter was marked the last calibration was performed in 2005. Your flow meter should be calibrated at least annually. Please have your flow meter calibrated.

➤ **The air diffusers for the lagoons require repair or replacement:**

As we discussed, the air diffusers in the lagoons require maintenance or replacement. There are different options to replace the diffusers. Repair of the existing ones may be too costly and replacement may be more economical.

If you have any comments or questions, please feel free to call me at (740) 380-5227.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IH00003*CD	OH0005967	May 15, 2007	C	S	2

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Carl Rittberger Sr Inc 1900 Lutz Lane Zanesville, Ohio 43701	11:00 AM	March 1, 2003
	Exit Time	Permit Expiration Date
	12:00 PM	February 29, 2008

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Andrew Rittberger, President	740-452-2767
Name, Address and Title of Responsible Official	Phone Number
Andrew Rittberger, President 1900 Lutz Lane Zanesville, Ohio 43701	740-452-2767


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>M</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N/A</u> Sludge Storage/Disposal	<u>N/A</u> Other
<u>N/A</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See attached letter.



Scott Foster, Inspector, Ohio EPA, Southeast District Office

5/24/07

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

5/24/07

Date