



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

March 8, 2007

**Re:** Muskingum County  
Westgate Terrace MHP  
CEI  
Permit No. 0PV00016\*AD  
NPDES No. OH0115410  
Correspondence (PWW)

Mr. David L. Cook, Owner  
Westgate Terrace MHP  
1826 South Main Street  
Akron, Ohio 44301

Dear Mr. Cook:

On February 20, 2007, Tim Campbell and I performed a compliance evaluation inspection at the Westgate Terrace Mobile Home Park. The purpose of the inspection was to determine your compliance with NPDES Permit Number 0PV00016.

At the time of the inspection, both sand filters were clogged and holding sewage. The south sand filter was running over into the north. This is a good indication that you have not corrected the inflow and infiltration (I/I) problems as required by the Director's Final Findings and Orders that you signed on March 17, 2003.

It has been noted that Enviroflow has been working on the I/I problems inside the collection system. In a letter dated November 9, 2006, you indicated to Mr. Campbell that your intention was to immediately act on their recommendations to eliminate the I/I.

In your response to this letter, please provide me with a copy of Enviroflow's recommendations and your schedule to complete the work items. Be advised that we will take formal enforcement action and recommend the assessment of monetary penalties if the I/I problems continue to cause effluent limitation violations.

I rated this facility unsatisfactory on the attached report due to the problems mentioned above. Please respond to this letter by April 1, 2007.

If you have any questions or comments, please do not hesitate to call me at (740) 380-5227.

Sincerely,



Scott Foster  
Environmental Specialist 2  
Division of Surface Water

SF/dh

Enclosure

c: Chris Hubner, Operator

**NPDES**  
Compliance Inspection Report

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PV00016*AD	OH0115410	February 20, 2007	C	S	1

**B. FACILITY DATA**

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Westgate Terrace Mobile Home Park 5971 National Road Zanesville, Ohio 43701	2:00 p.m.	March 1, 2003
	Exit Time	Permit Expiration Date
	2:30 p.m.	February 29, 2008

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Chris Hubner, Operator	(740) 255-6385
Name, Address and Title of Responsible Official	Phone Number
David L. Cook, Owner	(330) 773-3351

**C. AREAS EVALUATED DURING INSPECTION**

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>N</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>U</u> Compliance Schedules
<u>M</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>N</u> Self-Monitoring Program
<u>U</u> Facility Site Review	<u>N</u> Sludge Storage/Disposal	<u>N</u> Other
<u>U</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

**D. SUMMARY OF FINDINGS/COMMENTS** (attach additional sheets if necessary)


See attached letter.



Scott Foster, Inspector, Ohio EPA, Southeast District Office

3/9/07

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/9/07

Date