



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Laura H. Powell, Acting Director

January 22, 2007

Re: Morgan County
Stockport WWTP
2007 CEI
Correspondence (PWW)

Mayor and Council
Village of Stockport
P.O. Box 158
Stockport, Ohio 43787

Dear Mayor and Council:


On January 10, 2007, Tim Campbell and I conducted an inspection of the Stockport Wastewater Treatment Plant. A copy of the inspection report is attached. The purpose of the inspection was to determine the village's compliance with their NPDES Permit Number OPA00005*ID and to review the treatment facility and collection system performance for the upcoming permit renewal.

As a result, I have the following comments:

1. There have been excessive suspended solids violations. We discussed a plan to have sludge removed from the lagoon. Please keep Ohio EPA advised to the amounts of sludge and frequencies of removal. A sludge management plan is on file dated November 1987. Please check if there has been an update to this and forward to Ohio EPA.
2. As of the last inspection, a deadline of Spring 2007 was set for the completion of smoke testing and I/I investigation. Please update us on what has been completed.
3. There has been improvement with the amount of fecal coliform violations since the last inspection. Maintenance improvements have been noted and you are encouraged to continue your diligence on these actions.

Other than sludge management and the I/I in the village, I would rate your performance as improving overall. Please respond to this letter by February 7, 2007. Feel free to contact me at (740) 380-5227.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Foster", written over a horizontal line.

Scott Foster
District Engineer
Division of Surface Water

SF/dh

c: Robert Grove, Village Administrator

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPA00005*ID	OH0020249	January 10, 2007	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Stockport Wastewater Treatment Plant 830 East River Road Stockport, Ohio 43787	10:00 AM	August 1, 2002
	Exit Time	Permit Expiration Date
	11:00 AM	July 30, 2007

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Robert Groves, Operator	740-559-2773
Name, Address and Title of Responsible Official	Phone Number
Robert Groves, Village Administrator	740-559-2773


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>NA</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>NA</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>NA</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>M</u> Sludge Storage/Disposal	<u>—</u> Other
<u>M</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



 Scott Foster, Inspector, Ohio EPA, Southeast District Office

1/17/07

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

1-23-07

 Date