

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 20, 2011

Re: Meigs County
Rutland WWTP
NPDES permit 0PA00052*FD
Reconnaissance Inspection
Correspondence (PWW)

Mr. Gary Freeman
Village of Rutland WWTP
P.O. Box 420
Rutland, Ohio 45775

Dear Mr. Freeman:

On December 7, 2010, I conducted a compliance inspection of the Village of Rutland's wastewater treatment plant located on Davis Road in Rutland, Ohio. The purpose of the inspection was to determine the Village of Rutland's compliance with the Ohio Water Pollution Control Act, Ohio Revised Code Chapter 6111, and NPDES permit 0PA00052*FD. The results of the inspection are as follows:

1. There appeared to be a large amount of foam in the aeration chambers in the treatment plant.
2. Mr. Dewitt stated that Inflow and Infiltration (I/I) is still a significant problem in the system.
3. The village recently received a grant to replace 30 grinder pumps in the village. The village currently has around 295 grinder pumps. Mr. Dewitt stated that two to three pumps are being replaced per week. I would like to meet soon with your certified operator to discuss what problems you have had with the pumps that you are currently using to see if we could be of any assistance.

Attached is a checklist completed as a result of the inspection. If you have any questions, please contact me at (740) 380-5266.

Sincerely,



Cynthia Yandrich
District Representative
Division of Surface Water

CY/dh

Enclosure

**NPDES
Reconnaissance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPA00052*FD	OH0050130	December 7, 2010	R	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Rutland WWTP Davis Road, Rutland Meigs County, Ohio	12:39 p.m.	February 1, 2010
	Exit Time	Permit Expiration Date
	12:50 p.m.	January 31, 2015

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Ramone Dewitt	740-742-3136
Name, Address and Title of Responsible Official	Phone Number
Mr. Gary Freeman, Operator P.O. Box 420 Rutland, Ohio 45775	740-742-3136


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N/A</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N/A</u> Sludge Storage/Disposal	<u>N/A</u> Other
<u>N/A</u> Collection System		


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


Cynthia Yandrich, Inspector, Ohio EPA, Southeast District Office

11/19/11
Date


Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

11/19/11
Date