



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 27, 2009

Re: Meigs County
Syracuse-Racine Regional Sewer District
NPDES 0PQ00003*GD
Compliance Inspection
Correspondence (PWW)

Mr. Marvin Hale
Syracuse-Racine Regional Sewer District
P.O. Box 201
Racine, Ohio 45771

Mr. Hale:

On April 9, 2009, Ohio EPA inspected the Syracuse-Racine Regional Sewer District WWTP. The inspection was conducted in order to determine compliance with the Ohio Water Pollution Control Act, ORC chapter 6111. At that time, you and Mr. Richard Martin accompanied me through the plant, lab, and to the outfall for inspection. Two years of self monitoring data was also reviewed.

Based on observations made at that time, no apparent violations were noted. The conditions at the plant are documented in the attached checklist.

Ohio EPA is in receipt of a PTI application for plant improvements. This PTI application is currently being reviewed, and the final PTI should be issued in the near future.

If you have any questions, feel free to contact me at (740) 380-5447 or email mike.yandrich@epa.state.oh.us.

Sincerely,

Michael Yandrich
District Representative
Division of Surface Water

MY/dh

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PQ00003*GD	OH0050661	April 9, 2006	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Syracuse-Racine Regional WWTP Yellowbush Road, Sutton Township Meigs County	10:30 a.m.	August 1, 2006
	Exit Time	Permit Expiration Date
	12:30 p.m.	July 31, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Marvin Hale, Superintendent Richard Martin	(740) 949-2897
Name, Address and Title of Responsible Official	Phone Number
Marvin Hale Syracuse-Racine Regional WWTP P.O. Box 201 Racine, Ohio 45771	(740) 949-2897

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u> </u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>NA</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>N</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

The plant appears to be well maintained; Ohio EPA is currently reviewing a permit application for major improvements/rebuild at the plant, including pump stations, oxidation ditches, and belt filter press.



Mike Yandrich, Inspector, Ohio EPA, Southeast District Office

5-27-09

Date



Tim Campbell, Reviewer, Ohio EPA, Southeast District Office

5/27/09

Date