



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 19, 2008

Re: Meigs County
Eastern Local School District WWTP
NPDES permit OPT00046*BD
Inspection
Correspondence (PWW)

Mr. Ricky Edwards, Superintendent
Eastern Local School District
50008 State Route 681
Reedsville, Ohio 45772

Mr. Edwards:

On May 29, 2008, Ohio EPA conducted a compliance inspection of Eastern Local School District's wastewater treatment plant located at 38900 State Route 7. The purpose of the inspection was to determine Eastern Local Schools' compliance with the Ohio Water Pollution Control Act, Ohio Revised Code Chapter 6111, and NPDES permit OPT00046*BD. Mr. Brad Edwards accompanied me through the plant during the inspection. No violations were noted. However, you will need to address the following comments:

1. NPDES permit OPT00046*BD requires that the flow rate to the plant be recorded. Mr. Edwards stated that he has utilized the water meter to accomplish this. However, Mr. Edwards indicated that the school recently installed a sprinkler system to water the school's athletic fields, resulting in an inaccurate sewage flow reading. Eastern Local Schools will either need to install another meter to record water usage for sprinkler use (allowing this number to be subtracted from total water usage) or provide a meter at the headworks or discharge of the treatment plant.
2. The treatment plant must be under the supervision of a certified Class 1 operator, per Part II, A of your NPDES permit. Please ensure that Eastern Local Schools is meeting these staffing requirements. If this requirement is not being met, you will either need to hire a certified operator or allow school staff member(s) to attend classes necessary to obtain this certification and hire a certified operator in the interim. During the inspection, Mr. Edwards indicated a willingness to attend these classes if necessary. For information on Class 1 staffing and certification requirements, please call Ohio EPA's Operator Certification Hotline at (866) 411-6728.

Attached is a checklist completed as a result of the inspection.

If you have any questions, please contact me at (740) 380-5447.

Sincerely,



Michael Yandrich, P.E.
District Representative
Division of Surface Water

MY/dh

Enclosure

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00046*BD	OH0124796	May 29, 2008	S	1	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Eastern Local School District 38900 State Route 7 Reedsville, Ohio 45772	11:15 a.m.	August 1, 2006
	Exit Time	Permit Expiration Date
	12:08 p.m.	July 31, 2007

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Brad Edwards	
Name, Address and Title of Responsible Official	Phone Number
Ricky Edwards, Superintendent	(740) 667-6079

C. AREAS EVALUATED DURING INSPECTION

- | | | |
|--------------------------------------|---------------------------------------|-------------------------------------|
| <u> </u> S Permit | <u> </u> M Flow Measurement | <u> </u> NA Pretreatment |
| <u> </u> S Records/Reports | <u> </u> NA Laboratory | <u> </u> NA Compliance Schedules |
| <u> </u> S Operations & Maintenance | <u> </u> S Effluent/Receiving Waters | <u> </u> S Self-Monitoring Program |
| <u> </u> S Facility Site Review | <u> </u> S Sludge Storage/Disposal | <u> </u> Other |
| <u> </u> S Collection System | | |

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See attached inspection letter.



Mike Yandrich, Inspector, Ohio EPA, Southeast District Office

6-19-08

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

6/19/08

Date