

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 21, 2011

Re: Meigs County
Meigs High School WWTP
NPDES permit 0GV00015
Compliance Inspection
Correspondence (PWW)

Mr. Rusty Bookman, Superintendent
Meigs Local School District
41765 Pomeroy Pike
Pomeroy, Ohio 45769

Mr. Bookman:


On December 7, 2010, Ohio EPA conducted a reconnaissance inspection of Meigs High School District's wastewater treatment plant located behind the high school at 41765 Pomeroy Pike, Pomeroy, Meigs County, Ohio. The purpose of the inspection was to determine Meigs High Schools' compliance with the Ohio Water Pollution Control Act, Ohio Revised Code Chapter 6111, and NPDES permit 0PT00046*BD. Principal Steve Ohlinger accompanied me through the plant during the inspection. No violations were noted. However, you will need to address the following comments:

1. There was some sludge solids on the sand filters, but the effluent was still clear. Your current operator has been trying to contact the aeration unit supplier to see if they have recommendations; apparently he has not had much luck. I will also work with your operator to try to improve plant performance.
2. Your current general NPDES permit expired on December 31, 2009. You must submit an application for coverage under the general NPDES permit for Small Sanitary Dischargers. Please see our website at http://www.epa.ohio.gov/dsw/permits/GP_SmallSanitaryDischargers.aspx for details. I have attached the application form and fee schedule; these also can be found at <http://www.epa.ohio.gov/dsw/permits/gpfact.aspx>. Please call me if you have any questions.
3. Be advised the new general permit will require a Class A operator. At that time, you will be required to employ a licensed Class A operator for a minimum of 1 hour per week, two days per week. This operator must complete paperwork to be the operator of record, see attached.

Attached is an inspection report.

If you have any questions, please contact me at (740) 380-5266.

Sincerely,



Cynthia Yandrich
District Representative
Division of Surface Water

CY/dh

Enclosure

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0GV00015	OHV000002	December 7, 2010	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Meigs High School 41765 Pomeroy Pike Pomeroy, Ohio 45769	12:50 p.m.	January 1, 2007
	Exit Time	Permit Expiration Date
	11:08 p.m.	December 31, 2009

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Steve Ohlinger, Principal	740-992-2158
Name, Address and Title of Responsible Official	Phone Number
Mr. Rusty Bookman, Superintendent Meigs Local School District 41765 Pomeroy Pike, P.O. Box 272 Pomeroy, Ohio 45769	740-992-2153


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N/A</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N/A</u> Sludge Storage/Disposal	<u>N/A</u> Other
<u>N/A</u> Collection System		


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


Cynthia Yandrich, Inspector, Ohio EPA, Southeast District Office

1/20/11
Date


Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

4/19/11
Date