



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 7, 2008

**Re:** Adams County  
Adams Co. Valley Local School  
Storm Water Construction Activity  
Notice of Violation  
OGC01053\*AG

Mr. Charles Kimble  
141 Lloyd Road  
West Union, Ohio 45693

Dear Mr. Kimble:

On July 10, 2008, I visited your site on Dragon Lair Drive. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Part III.G.2.b. The permit requires that any area within 50 feet of a stream that will remain dormant for more than 21 days be stabilized within 2 days of the most recent disturbance. **Immediately stabilize the area behind sediment pond that is beside the creek.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5418

Sincerely,

Philip Webb  
Storm Water Section  
Division of Surface Water

PW/dh