



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 23, 2008

Re: Adams County
McDonalds Seaman
Storm Water Construction Activity
Notice of Violation
OGC01118*AG

Mr. Dave Warren
McDonalds USA LLC
2 Easton Oval, Suite 200
Columbus Ohio 43219

Dear Mr. Warren:

On June 11, 2008, I visited your site on 17111 SR 247. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. The permit requires the Storm Water Pollution Prevention Plan to include a description of every sediment and erosion control that will be utilized on your construction site throughout the course of the project (Part III.G.2). The SWP3 must outline the proper use of the control; it should describe at what time during the project the control(s) will be implemented; and which contractor is responsible for the construction and maintenance of the control(s). Submit a copy of your plan for review.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh