



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 26, 2008

**Re: Athens County  
Hocking College Foundation  
Storm Water Construction Activity  
Notice of Violation  
OGC00464\*AG**

Dr. Roy Palmer  
3301 Hocking Parkway  
Nelsonville, Ohio 45764

Dear Dr. Palmer:

On June 18, 2008, I visited your site on 3301 Hocking Parkway. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.
2. Part III.G.2.d.ii of the permit requires concentrated runoff and runoff from drainage areas, which exceed the design capacity of silt fence or inlet protection, to be conveyed to a sediment settling pond. Sites over 10 acres must install a sediment pond. Sediment ponds must be capable of holding 67 cubic yards of storage per on site and off site drainage acre. Sediment must be removed from the sediment pond when the design capacity has been reduced by 40 percent (this is typically reached when the pond is half full). Dig out the sediment pond on the north side on the construction site.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5418.

Sincerely,



Philip Webb  
Storm Water Section  
Division of Surface Water

PW/dh