



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 29, 2007

Re: Belmont County
Ohio Heat Transfer
Storm Water Construction Activity
Notice of Violation
0GC00964*AG

Mr. Mark Epure
Ohio Heat Transfer
3400 Port Union Road
Hamilton, Ohio 45014

Dear Mr. Epure:

On August 14, 2007, I visited your site at the Fox Commercial Park in Belmont County. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for the discharge of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. **The perimeter needs storm water controls such as silt fence to prevent sediment pollution.** Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual.
2. **The construction entrance lacked sufficient aggregate. This must be corrected to prevent further off site tracking.** Part III.G.2.g.ii. of the permit requires that off-site vehicle tracking of sediments be minimized. This is accomplished by constructing a proper construction entrance. The *Rainwater and Land Development* manual defines a construction entrance as a pad of aggregate 6 inches deep, 10 feet wide and 50 feet in length (30 feet for single residence lots).

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 385-8501 or Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in cursive script, appearing to read "Nathan Weber".

Nathan Weber
Storm Water Section
Division of Surface Water

NW/dh