



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 1, 2008

Re: Gallia County  
Gallipolis City School  
Storm Water Construction Activity  
OGC00577\*AG

Mr. Jack Payton  
61 State Street  
Gallipolis, Ohio 45631

Dear Mr. Payton:

On July 16, 2008, I visited the site located on 2855 Centenary Road. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area within 50 feet of a stream that will remain dormant for more than 21 days be stabilized within 2 days of the most recent disturbance. **Areas adjacent to the streams must meet the above requirement.**
2. Detailed drawings and maintenance plans must be provided for all post-construction BMPs. Part III.G.2.e. of the permit states that post-construction storm water practices must provide perpetual management of runoff quality and quantity. These plans and drawings should be provided by the permittee to the post construction operator of the site. **Please Submit a detail drawing of permanent stormwater ponds and discharge structures.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5418.

Sincerely,

Philip Webb  
Storm Water Section  
Division of Surface Water

PW/dh