



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 31, 2007

Re: Harrison County
HAS-CR29-0.01, PID 77607, DIST 11
Storm Water Construction Activity
Notice of Violation
OGC00648*AG

Mr. Jeff Lechak
ODOT District 11
2201 Reiser Avenue SE
New Philadelphia, Ohio 44663

Dear Mr. Lechak:

On August 22, 2007, Nathan Weber, of this office, and I visited your site on Industrial Park Drive near Cadiz. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for the discharge of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. **The silt fence was down in some areas and must be reinstalled correctly and maintained until construction is complete and the entire upslope area is stabilized.** Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual.
2. **All areas that will lie dormant for more than 21 days must be stabilized. Seed and mulch all areas that do not meet this requirement.** Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 385-8501 or Aaron Wolfe at (740) 380-5277.

Sincerely,



Michael Campbell
Storm Water Section
Division of Surface Water

MC/dh