



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

July 24, 2007

Re: Jackson County
Veterans Substation
Stormwater Construction Activity
Notice of Violation
OGC00530*AG

Mr. Steven Benson
City of Jackson
145 Broadway Street
Jackson, Ohio 45640

Dear Mr. Benson:


On July 12, 2007, I visited your site on Veterans Drive. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for the discharge of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. **The silt fence on the back of the site is down and needs to be reinstalled properly.** Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual.
2. **The back of the lot appears to have been dormant for some time. Temporary stabilization needs to be applied to any disturbed area that will lie dormant for more than 21 days.** Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.
3. **Permanently stabilize all disturbed areas that are at final grade.** Part III.G.2.b.i (Table 1) of the permit requires that permanent stabilization be applied to areas at final grade within 7 days of the last disturbance. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 385-8501 or Aaron Wolfe at (740) 380-5277.

Sincerely,



Michael Campbell
Stormwater Section
Division of Surface Water

MC/dh