



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 19, 2008

**Re: Jackson County
Holzer Medical
Storm Water Construction Activity
Notice of Violation
0GC00655*AG**

Mr. Jim Blevins
90 Jackson Pike
Gallipolis, Ohio 45631

Dear Mr. Blevins:

On July 22, 2008, I visited your site on Pattonsville Road. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. **Immediately seed the hillside adjacent to state highway 35.**
2. Part III.G.2.d.iv. of the permit states that sediment control practices must minimize the amount of sediment entering an active storm drain system, unless the system drains to a sediment settling pond. **Assess all inlet protection for proper controls and make corrections as needed.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

Philip Webb
Storm Water Section
Division of Surface Water

PW/dh