



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 1, 2008

Re: Muskingum County
Time Warner Zanesville Call Center
Storm Water Construction Activity
Notice of Violation
0GC01081*AG

Ms. Jennifer Allen
M/E Properties LLC
P.O. Box 8025
Zanesville, Ohio 43701

Dear Ms. Allen:

On July 14, 2008, I visited your site on Northpointe Dr. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:

1. Part III.G.2.g.ii. of the permit requires that off-site vehicle tracking of sediments be minimized. This is accomplished by constructing a proper construction entrance. The Rainwater and Land Development manual defines a construction entrance as a pad of aggregate 6 inches deep, 10 feet wide and 50 feet in length (30 feet for single residence lots). **There is mud and stone being tracked onto the road from your site. Install a sufficient construction entrance immediately.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5430.

Sincerely,



Joe May
Storm Water Section
Division of Surface Water

JM/dh