



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 1, 2008

**Re:** Muskingum County  
Flinton Equipment  
Storm Water Construction Activity  
Notice of Violation  
0GC00970\*AG

Mr. Kevin Annett  
Flinton Equipment  
999 Zane Street  
Zanesville, Ohio 43701

Dear Mr. Annett:

On July 14, 2008, I visited your site on Northpointe Drive. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

**Permit Coverage:**

Part III.G.2.b.i (Table 1) of the permit requires that permanent stabilization be applied to areas at final grade within 7 days of the last disturbance. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control. **Seed and mulch any areas that do not meet this requirement.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5430.

Sincerely,

Joe May  
Storm Water Section  
Division of Surface Water

JM/dh