



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

July 24, 2007

**Re:** Muskingum County  
Kimble Subdivision  
Stormwater Construction Activity  
Notice of Violation  
0GC00331\*AG

Mr. Brent Kimble  
3435 Ragans Way  
Zanesville, Ohio 43701

Dear Mr. Kimble:

On July 11, 2007, I visited your site at the intersection of Dresden and Hale Roads, north of Zanesville. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for the discharge of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. **A sediment pond must be in place for your site. This is needed for post construction stormwater treatment.** In accordance with Part III.G.2.e. of the permit, all sites over five acres must have post-construction BMPs capable of detaining runoff for the protection of stream channels, stream erosion control, and improved water quality. Such BMPs may include a water quality basin.
2. **Stormwater inlets must be protected from sediment pollution if there is not a sediment pond present.** Part III.G.2.d.iv. of the permit states that sediment control practices must minimize the amount of sediment entering an active storm drain system, unless the system drains to a sediment settling pond.
3. **There were areas of disturbed ground that appear to be dormant. They must be temporarily stabilized.** Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 385-8501 or Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in cursive script, appearing to read "Nathan Weber".

Nathan Weber  
Stormwater Section  
Division of Surface Water

NW/dh