



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 5, 2010

Re: Perry County
PVRSD Project
Stormwater Construction Activity
Notice of Violation
OGC01174*AG

Fields Excavating, Inc.
177 Township Road 191
Kitts Hill, Ohio 45645

To whom it may concern:

On March 30, 2010, I visited the Slate Mills and Green Acres Project. The purpose of the inspection was to determine the compliance of these sites with the National Pollutant Discharge Elimination System (NPDES) permits for the discharge of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Violators of ORC 6111 may be fined up to \$10,000 per day of violation. In addition, federal law allows for third party lawsuits for failure to comply with terms and conditions of NPDES permits.

I found the following violations:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.

Portions of the project did not meet this requirement. Assess the entire project and stabilize accordingly.

2. Part III.G.2.b.ii. of the permit states that operators shall stabilize channels and outfalls to prevent erosive flows. Techniques may include seeding, mulching, erosion control matting, sodding, rip rap, or rock check dams.

Stabilize the area near the pump station. The pump station area was dewatered during construction creating erosion issues.

3. Part III.G.2.b.i. (Table 2) of the permit requires that any area within 50 feet of a stream that will remain dormant for more than 21 days be stabilized within 2 days of the most recent disturbance.

Portions of the project did not meet this requirement. Assess the entire project and stabilize accordingly.

4. Part III.G.2.h of the permit states that all sediment control practices must be maintained and repaired until the entire up slope area of the development has been stabilized. According the Part III.G.2.i. of the permit, controls must be inspected once every seven calendar days and within 24 hours after any storm event greater than one half an inch in 24 hours. Repairs must be accomplished within three days of the inspection, except in the case of sediment ponds, which must be repaired within 10 days. In accordance with Part III.G.2.d.vi., if inspections or other information indicates that a control is not functioning or ineffectual, then the permittee must replace or modify the control.

Submit copies of your inspection reports for the past three months.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5277.

Sincerely,



Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh

c: Jeff Raines, Pleasant Valley Regional Sewer District