



State of Ohio Environmental Protection Agency

O.E.P.A.
S.E.D.O.

2008 OCT -2 AM 11:28

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 19, 2008

Re: Ross County
Adena Station
Storm Water Construction Activity
Notice of Violation
OGC01065*AG

Mr. Don Kendall
American Electric Power
1 Riverside Plaza
Columbus, Ohio 43215

Dear Mr. Kendall:

On September 2, 2008, I visited your site at 110 Limestone Drive. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. **Stabilize all areas that meet the above requirements.**
2. Part III.G.2.b.i. (Table 1) of the permit requires that permanent stabilization be applied within 7 days to any area that will lie dormant for more than one year. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control. **Reseed any necessary areas to be in compliance with your permit.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Adena Station
Page 2

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5430.

Sincerely,



Joe May
Storm Water Section
Division of Surface Water

JM/dh