



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 19, 2008

Re: Tuscarawas County
City of Dover WWTP
Storm Water Construction Activity
Notice of Violation
3GC03054*AG

Mr. Bill Craig
City of Dover
116 E. 3rd Street
Dover, Ohio 44266

Dear Mr. Craig:

On a August 6, 2008, I visited your site on 100 N. Tuscarawas Avenue. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:

1. Part III.G.2.h of the permit states that all sediment control practices must be maintained and repaired until the entire up slope area of the development has been stabilized. According to Part III.G.2.i. of the permit, controls must be inspected once every seven calendar days and within 24 hours after any storm event greater than one half an inch in 24 hours. Repairs must be accomplished within three days of the inspection, except in the case of sediment ponds, which must be repaired within 10 days. In accordance with Part III.G.2.d.vi., if inspections or other information indicates that a control is not functioning or ineffectual, then the permittee must replace or modify the control. **Assess the silt fence along the river for compliance with the permit and repair and/or replace as needed.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5430.

Sincerely,



Joe May
Storm Water Section
Division of Surface Water

JM/dh