



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 4, 2008

**Re:** Washington County  
Microtel Inn & Suites  
Storm Water Construction Activity  
Notice of Violation  
0GC01139\*AG

Mr. Stephen Keiser  
Martel Lodging, Ltd.  
329 S. Seventh Street  
Marietta, Ohio 45750

Dear Mr. Keiser:

On July 8, 2008, I visited your site on 506 Pike Street. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

**Permit Coverage**

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. Stabilize all areas that meet this criteria.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5430.

Sincerely,

Joe May  
Storm Water Section  
Division of Surface Water

JM/dh