



State of Ohio Environmental Protection Agency

---

**Southeast District Office**


---

2195 Front Street  
Logan, Ohio 43138TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.usTed Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 4, 2008

**Re: Washington County  
Burt Buildings  
Storm Water Construction Activity  
Notice of Violation  
OGC00387\*AG**

Mr. Dave Burt  
Walsh Construction  
8734 Dupont Road  
Washington, WV 26181

Dear Mr. Burt:

On July 8, 2008, I visited your site on S.R. 339. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

**Permit Coverage**

1. Part III.G.2.b.i (Table 1) of the permit requires that permanent stabilization be applied to areas at final grade within 7 days of the last disturbance. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control. **Seed all areas that are at final grade.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5430.

Sincerely,

Joe May  
Storm Water Section  
Division of Surface Water

JM/dh