



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 25, 2009

**Re:** Washington County  
Ohio Power Wolf Creek Station  
Storm Water Construction Activity  
Notice of Violation  
0GC01266\*AG

Steve Ford  
Ohio Power  
1 Riverside Plaza  
Columbus, OH 43215

Dear Mr. Ford:

On July 27, 2009, I visited your site on 3502 Wells Road near Waterford. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

**Permit Coverage**

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. **The soil stock pile has been dormant for some time and needs to be stabilized immediately.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above-mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226.

**Please be advised that failure to comply with the terms and conditions of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.**

Sincerely,

A handwritten signature in black ink, appearing to read "Michael See", with a long horizontal flourish extending to the right.

Michael See  
Storm Water Section  
Division of Surface Water

MS/mlm