



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

September 16, 2010

Re: Washington County
Duck Creek #1
Storm Water Construction Activity
OGC00322*AG

Mr. Kenneth Strahler
Ken Strahler Masonry, Inc.
116 Alta Street
Marietta, Ohio 45750

Dear Mr. Strahler:

On August 30, 2010, I visited the Duck Creek #1 site off Hunter Avenue in Marietta, Ohio. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues.

As a reminder if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements for permanent storm water management structures as required by the permit.

If there are any questions, please contact me at (740) 390-5430 or Aaron Wolfe at (740) 380-5277.

Sincerely,

L.J. Parkins
Storm Water Section
Division of Surface Water

LJP/dh