



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 5, 2010

Re: Pike County
Piketon WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PB00031*FD
Correspondence (PWW)

Ms. Rhonda Clemmons
Village of Piketon
109 E. Third Street
Piketon, Ohio 45661

Dear Ms. Clemmons:

We have reviewed your self-monitoring reports covering the months of April through June 2010 for the Piketon Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	7D Conc	2000	7700.	5/8/2010
001	31616	Fecal Coliform	7D Conc	2000	3800.	6/8/2010
001	31616	Fecal Coliform	7D Conc	2000	6200.	6/15/2010

* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,


Jack Knapp
District Representative
Division of Surface Water

JK/dh