

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

March 9, 2011

**Re:** Pike County  
Pike Water, Inc.  
Permit #0IY00052\*ED  
WWTP Inspection  
Correspondence (PWW)

Mr. Timothy Williams, General Manager  
Pike Water, Inc.  
P.O. Box 19  
Waverly, Ohio 45690

Dear Mr. Williams:

On February 9, 2011, I conducted an inspection of the Jasper Elementary wastewater treatment plant (WWTP). David Baldwin represented Pike Water, Inc. and assisted me during the inspection. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number 0IY00052\*ED. A copy of the inspection report is attached.

If there are any questions, please call me at (740) 380-5268.

Sincerely,

Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

Enclosure: Compliance Inspection Report

**NPDES  
Compliance Inspection Report**

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
01Y00052*ED	OH0094561	February 9, 2011	C	S	1

**B. FACILITY DATA**

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Pike Water Inc 8539 State Route 104 Waverly, Ohio 45690	9:45 a.m.	August 1, 2008
	Exit Time	Permit Expiration Date
	10:00 a.m.	July 31, 2014

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
David Baldwin, Operator	(740) 947-2524
Name, Address and Title of Responsible Official	Phone Number
Mr. Timothy Williams, General Manager Pike Water Inc P.O. Box 19 Waverly, Ohio 45690	(740) 947-2524

**C. AREAS EVALUATED DURING INSPECTION**

<u>  </u> S Permit	<u>  </u> S Flow Measurement	<u>  </u> N/A Pretreatment
<u>  </u> S Records/Reports	<u>  </u> S Laboratory	<u>  </u> N/A Compliance Schedules
<u>  </u> S Operations & Maintenance	<u>  </u> S Effluent/Receiving Waters	<u>  </u> S Self-Monitoring Program
<u>  </u> S Facility Site Review	<u>  </u> S Sludge Storage/Disposal	<u>  </u> Other
<u>  </u> N/A Collection System		


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

**D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)**

Pike Water Inc. maintains a log book for their pH meter and calibrates the meter per the manufacturers specifications.

  
 \_\_\_\_\_  
 Jack Knapp, Inspector, Ohio EPA, Southeast District Office

3/10/11  
 \_\_\_\_\_  
 Date

  
 \_\_\_\_\_  
 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/10/11  
 \_\_\_\_\_  
 Date