

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 8, 2011

**Re:** Pike County  
City of Waverly  
Ohio EPA Permit No. 0PC00011\*HD  
NPDES Permit No. OH0023353  
Compliance Evaluation Inspection  
Correspondence (PWW)

Mayor and Council  
City of Waverly  
211 West North Street  
Waverly, Ohio 45690

Dear Mayor and Council:

On May 24, 2011, I performed a compliance evaluation inspection of the Wastewater Treatment Plant (WWTP) serving the City of Waverly. John Voorhes, plant superintendent, represented the City of Waverly and accompanied me during the inspection. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number 0PC00011\*HD. A compliance inspection report is enclosed with this letter.

The marginal rating given for the collection system is due to the excessive amount of Inflow/Infiltration (I/I) in the collection system. The city should continue to work on eliminating sources of I/I.

If there are any questions, please call me at (740) 380-5268

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

Enclosure

c: John Voorhes, Plant Superintendent, City of Waverly

# NPDES Compliance Inspection Report

## A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PC00011*HD	OH0023353	May 24, 2011	C	S	1

## B. FACILITY DATA

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
Waverly WWTP 9434 St. Rte. 220 Waverly, Ohio 45690	12:30 p.m.	August 1, 2009
	Exit Time	Permit Expiration Date
	2:30 p.m.	January 31, 2014

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
John Voorhes, Superintendent	(740) 947-4403
Name, Address, & Title of Responsible Official	Phone Number
Mayor and Council City of Waverly 211 West North Street Waverly, Ohio 45690	(740) 947-3193


## C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>    </u> Other
<u>M</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

## D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.

  
\_\_\_\_\_  
Jack Knapp, Inspector, Ohio EPA, Southeast District Office

5/27/11  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

6/7/11  
\_\_\_\_\_  
Date

**E. PERMIT VERIFICATION**

Inspection Observations Verify the Permit	YES	NO	N/A	N/E
a. Correct name & mailing address of permittee	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Correct name & location of receiving waters	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Product(s) & production rates conform with permit application (industries)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Flows & loadings conform with NPDES permit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Treatment processes are as described in permit application/briefing memo	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. New treatment process(es) added since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
g. Notification given to state of new, different, or increased discharges	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
h. All discharges are permitted	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Number & location of discharge points are as described in permit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

**F. COMPLIANCE SCHEDULES/VIOLATIONS**

	YES	NO	N/A	N/E
a. Any significant violations since the last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Permittee is taking actions to resolve violations	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Permittee has compliance schedule	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Compliance schedule contained in: _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e. Permittee is meeting compliance schedule	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

**G. OPERATION AND MAINTENANCE**

Treatment Facility Properly Operated & Maintained	YES	NO	N/A	N/E
a. Standby power available: Generator: <input checked="" type="checkbox"/> Dual Feed: <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Adequate alarm system available for power or equipment failures	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. All treatment units in service other than backup units	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Sufficient operating staff provided: # of shifts: <u>1</u> Days/Week: <u>5</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Operator holds unexpired license of class required by permit. Class: <u>III</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Copy of certificate of Operator of Record displayed on-site	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
g. Minimum operator staffing requirements fulfilled (OAC 3745-7)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
h. Routine & preventive maintenance schedule/performed on time	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Any major equipment breakdown since last inspection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
j. Operation & maintenance manual provided & maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
k. Any plant bypasses since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
l. Regulatory agency notified of bypasses: On MORS: <input type="checkbox"/> 800 No.: <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
m. Any hydraulic and/or organic overloads experienced since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

The plant recently lost the screw auger in the head works.

Record Keeping	YES	NO	N/A	N/E
a. Log book provided	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Log book kept on-site	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Log book contains the following:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1. Identification of treatment works	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Date/Time of arrival/departure of ORC	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Daily record of operation and maintenance activities	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Laboratory results (unless documented on bench sheets)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Identification of person making log entries	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Is the ORC submitting written notification to Ohio EPA and permittee when a collection system overflow, treatment plant bypass or effluent limit violation has occurred.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

Collection System	YES	NO	N/A	N/E
a. Percent combined system. Percent: <u>0</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Any collection system overflows since last inspection: CSO: <input type="checkbox"/> SSO: <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Regulatory agency notified of overflow (SSOs)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. CSO O&M plan provided and implemented	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e. CSOs monitored and reported in accordance with permit	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
f. Portable pumps used to relieve system	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
g. Lift station alarm systems provided and maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
h. Are lift stations equipped with permanent standby power or equivalent	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Is there an inflow/infiltration problem (separate sewer system), or were there any major repairs to collection system since last inspection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
j. Any complaints received since last inspection of basement flooding	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
k. Are any portions of the sewer system at or near capacity	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

The city is looking into slip lining problem areas in the collection system.

## H. SLUDGE MANAGEMENT

	YES	NO	N/A	N/E
a. Sludge adequately disposed. Method: <u>Landfill</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. If sludge is incinerated, where is ash disposed of? _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Is sludge disposal contracted? Name: _____	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Has amount of sludge generated changed significantly since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Adequate sludge storage provided at facility	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Land application sites monitored and inspected per state rules	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
g. Records kept in accordance with state rules	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
h. Any complaints received in last year regarding sludge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Is sludge adequately processed (digestion, dewatering, pathogen control) in accordance with Ohio EPA rules	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

**L. SAMPLING PROCEDURES (FOR CSI'S)**

- Grab samples obtained
- Composite obtained
- Compositing frequency: \_\_\_\_\_  
Preservation: \_\_\_\_\_
- Flow proportioned sample obtained
- Automatic sampler used
- Sample split with permittee
- Chain of custody employed
- Sample obtained from facility sampling device
- Sample refrigerated during compositing:  Yes  No
- Sample representative of volume & nature of discharge:

**Comments:**

# General Lab Criteria

Facility: Waverly WWTP

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Balance</b>		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<b>M</b>
• Standard Weights	• Either NIST Class s or ASTM/ANSI Class 1 weights <sup>1,2</sup>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
• Calibration Frequency/ Documentation.	• Calibration verification required at least once each day the balance is used <sup>3</sup>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
• Cleanliness, air movement, vibration	• Cleanliness of balance is a must and air movement and vibration needs to be kept to a minimum <sup>1</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Service and recalibrate annually (manufacturer representative or comparable) <sup>1</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Must be able to measure to 0.1 grams <sup>4</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Log book maintained <sup>6</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: The city should look into purchasing a couple of weights to calibrate the balance with each use.			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Drying Oven (Suspended Solids)</b>		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<b>A</b>
• Temperature Recordkeeping	• Temperature recorded with each use <sup>4</sup>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	• Log book maintained <sup>6</sup>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
• Calibration Frequency/ Documentation	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup> . Correction factor posted on thermometer/equipment <sup>1</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Thermometer temperature in 0.1°C increments <sup>5</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range is 103° – 105°F <sup>4</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: The wwtp should purchase a log book to record the temp. with each use.			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>pH Meter</b>		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>A</b>
• Calibration Frequency/ Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) <sup>3</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Log book maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Minimum of 2 point calibration	• Calibration per manufacturer specification and calibration buffers must bracket anticipated result <sup>7</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Slope Documentation/ Acceptability	• Slope acceptable range indicated on benchsheet <sup>2</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Buffer Expiration Date	• Buffers must not be expired	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Teflon covered magnetic stirrer or equivalent for mixing <sup>8</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments:			

## General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Dissolved Oxygen Meter</b>			
• Calibration Method	• Air or known DO calibration method <sup>10</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>A</b>
	• Calibration per manufacturer specification <sup>10</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Calibration Frequency/ Documentation	• Logbook maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration verification required at least once each day the meter is used. <sup>3</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Small to no bubble present under membrane (must be smaller than the lead in number 2 pencil) <sup>11</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments:			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Incubator (CBOD/E-Coli)</b>			
• Temperature Recordkeeping	• Temperature checked/recorded twice daily for each shelf in use <sup>1</sup>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<b>A</b>
	• Temperature checked/recorded daily <sup>2</sup> (CBOD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (CBOD) is 20°C ±1.0° <sup>12</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (E-Coli) is 35°C ±0.5° <sup>22</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Logbook maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Temperature Calibration/ Documentation	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature correction information posted on incubator <sup>1</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• E-Coli can use multiple tubes (five 20 ml or ten 10 mg), or mfg's multi-well tray	• E-coli Ultraviolet lamp (365 nm wave length, 6 W bulb) <sup>23</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature Log (thermometer reads to 0.1 Celsius) <sup>5</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments:			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Refrigerator</b>			
• Temperature Recordkeeping	• Temperature Log (thermometer reads to 0.1 Celsius) <sup>5</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>A</b>
• Temperature Calibration/ Documentation	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Thermometer held in water bath <sup>1</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Refrigerator temperature ±6° Celsius <sup>13</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Do not store volatile solvents, food, or beverages <sup>14</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments:			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Chlorine Meter</b>			
• Calibration Frequency/ Documentation	• pH/millivolt meter read to 0.1 mV <sup>15</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) <sup>3</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Calibration Method	• Calibration using three iodate solutions 0.2, 1.0, 5.0 milliliters	<input type="checkbox"/> Yes <input type="checkbox"/> No	

## General Lab Criteria

	or calibration per manufacturer specification <sup>16</sup>			
• Slope Documentation/ Acceptability	• Standards used for calibration not expired	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Calibration curve (acceptable slope)	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Electrode free of deposits and foreign material	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained <sup>9</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments:				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Ammonia Meter</b>				<b>A</b>
• Calibration Frequency/ Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) <sup>3</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Slope Acceptability	• Verify calibration slope is acceptable (per mfg. spec.)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Method	• Standards used for calibration (3 ammonia solutions of 10 mg/l, 1 mg/l, and 0.1 mg/l) or per mfg. spec. <sup>17</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Standards used for calibration not expired	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Electrode free of deposits and foreign material	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Teflon covered magnetic stirrer or equivalent for mixing <sup>18</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments:				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Sample Collection/Handling</b>				<b>A</b>
• Sample Labeling	• Samples container labeled (description, date, time, preservative added, initialed) <sup>19</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Chain of Custody	• Chain of custody (description, date, time, signature) <sup>19</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Composite samples refrigerated during sample collection <sup>14</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Equipment blanks utilized <sup>14</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• SOP for cleaning of sampling equipment	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments:				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Desiccator</b>				<b>A</b>
• General Criteria	• Properly working seals	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Desiccant fresh (blue color)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Documentation	• Log book being maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments:				

## General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Bench Sheets</b>			
<ul style="list-style-type: none"> <li>• General Criteria</li> </ul>	<ul style="list-style-type: none"> <li>• Date(s)<sup>2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>A</b>
	<ul style="list-style-type: none"> <li>• Analyst initials<sup>2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	<ul style="list-style-type: none"> <li>• Blue or black ink pen<sup>2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	<ul style="list-style-type: none"> <li>• Calibration information<sup>2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	<ul style="list-style-type: none"> <li>• Equations, calculations, units for all measurements, notations, and results present<sup>2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	<ul style="list-style-type: none"> <li>• Corrections, single line through, initialed and dated<sup>2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: Some information is logged onto a computer.			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Hot Water Bath (Fecal Coliform/E. Coli)</b>			
<ul style="list-style-type: none"> <li>• Temperature Recordkeeping</li> </ul>	<ul style="list-style-type: none"> <li>• Temperature Log (thermometer reads 0.2° C)<sup>21</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>A</b>
		<ul style="list-style-type: none"> <li>• Incubator temperature 44.5° C ±0.2°<sup>21/24</sup></li> </ul>	
<ul style="list-style-type: none"> <li>• Temperature Calibration/ Documentation</li> </ul>	<ul style="list-style-type: none"> <li>• Thermometer calibrated annually with NIST traceable thermometer<sup>1,2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		<ul style="list-style-type: none"> <li>• Log book being maintained<sup>9</sup></li> </ul>	
<ul style="list-style-type: none"> <li>• Water Level</li> </ul>	<ul style="list-style-type: none"> <li>• Thermometer total immersion or partial (line on thermometer to ID immersion depth)<sup>1,5</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments:			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Autoclaves/Steam Sterilizers</b>			
<ul style="list-style-type: none"> <li>• All apparatus utilized is adequately sterilized before use</li> </ul>	<ul style="list-style-type: none"> <li>• Sterilizing temperature 121° C<sup>25</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>A</b>
		<ul style="list-style-type: none"> <li>• 10 to 30 minutes time based on material being sterilized<sup>26</sup></li> </ul>	
<ul style="list-style-type: none"> <li>• Documentation</li> </ul>	<ul style="list-style-type: none"> <li>• Verify the autoclave temperature weekly by using a maximum registering thermometer (MRT) to confirm that 121°C has been reached as measured in the exhaust<sup>1</sup></li> </ul>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
		<ul style="list-style-type: none"> <li>• Date, contents, sterilization time and temperature, total time in autoclave, and analyst's initials should be recorded each time the autoclave is used<sup>1</sup></li> </ul>	
<ul style="list-style-type: none"> <li>• Temperature Calibration/ Documentation</li> </ul>	<ul style="list-style-type: none"> <li>• Thermometer calibrated annually with NIST traceable thermometer<sup>1,2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		<ul style="list-style-type: none"> <li>• Log book being maintained<sup>9</sup></li> </ul>	
<ul style="list-style-type: none"> <li>• Performance Checks</li> </ul>	<ul style="list-style-type: none"> <li>• Test monthly for efficacy using a biological such as commercially available <i>Geobacillus stearothermophilus</i> in spore strips, suspensions, or capsules<sup>1</sup></li> </ul>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Comments:			

## General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Final Effluent Temperature Monitoring</b>			
<ul style="list-style-type: none"> <li>• General Criteria</li> </ul>	<ul style="list-style-type: none"> <li>• Thermometer calibrated annually with NIST traceable thermometer<sup>1,2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>A</b>
	<ul style="list-style-type: none"> <li>• Thermometer reads in increments of at least 0.1°C<sup>5</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	<ul style="list-style-type: none"> <li>• Log book being maintained<sup>2</sup></li> </ul>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments:			

<b>Number of Criteria Rated:</b>	<b>Acceptable</b>	12
	<b>Marginal</b>	1
	<b>Unacceptable</b>	
<b>Total Number of Areas Rated</b>		13

<b>Acceptable Ratings</b> – No action required (recommend SOP's written or updated, perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, written response not required).	
<b>Marginal Ratings</b> – Improvements required, written response required (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response).	
<b>Unsatisfactory Rating</b> – Improvements required, written response required, NOV issued (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response to NOV).	
Consider recommending PAI Audit from DES when:	<ul style="list-style-type: none"> <li>&gt;60% of ratings are Marginal</li> <li>&gt;45% of ratings are a combination of Marginal or Unacceptable</li> <li>&gt;30% of ratings are Unacceptable</li> </ul>

# General Lab Criteria

## Notation of Referenced Method

1	Method 9020-B, Item 4	14	Method 1060A, Item 1
2	Method 1020-A, Item 1	15	Method 4500-CI I, Item 2
3	Method 1020-B, Item 10	16	Method 4500-CI I, Item 4
4	Method 2540-B, Item 2	17	Method 4500-NH3 D, Item 4
5	Method 2550-B, Item 1	18	Method 4500-NH3 D, Item 2
6	Method 1020-B, Item 1	19	Method 1060-B, Item 2
7	Method 4500-H B, Item 4	20	Method 1060-B, Item 1
8	Method 4500-H B, Item 2	21	Method 9222D, Item 1
9	Method 1020-B, Item 2	22	Method 9223 B, Item 2
10	Method 4500-O B, Item 3	23	Method 9223 B, Item 3
11	Method 4500-O G, Item 3	24	Method 1603, Item 2
12	Method 5210-B, Item 5	25	Method 9030-B, Item 3
13	CFR 136.3, Table II	26	Method 9020 B, Table IV

Equipment Logbook Content – All maintenance performed on a piece of equipment should be documented in the logbook. This should include parts replacement and routine maintenance activities. Entries should include date, maintenance performed and initials of person making entry.

Preservation and Holding Times						
Parameter	Container	Min. Sample Size (mL)	Sample Type	Preservation	Maximum Storage Time	
					Recommended	Regulatory
BOD / CBOD	P, G	1000	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	6h	48h
TSS	P, G	200	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 d
pH	P, G	50	G	Analyze immediately	0.25h	0.25 h
NH3-N	P, G	500	G, C	Analyze as soon as possible or add $\text{H}_2\text{SO}_4$ to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	28 d
TRC	P, G	500	G	Analyze immediately	0.25h	0.25 h
DO (electrode)	G, BOD Bottle	300	G	Analyze immediately	0.25h	0.25 h
Temperature	P, G	--	G	Analyze immediately	0.25h	0.25 h
Metals, general	P, G	1000	G, C	For dissolved filter immediately and add $\text{HNO}_3$ to pH <2	6 months	6 months
Purgeables by purge and trap	G (PTFE lined lid)	40 (X2)	G	HCl to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	14 d
Base/Neutrals and acids	G (solvent rinsed or baked)	1000	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Pesticides	G (PTFE lined lid)	1000	C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Fecal Coliform / E-Coli	G, P (Sterilized)	100	G	Refrigerate $\leq 10^{\circ}\text{C}$ If chlorine present, add sodium thiosulfate tablet	6 hrs transport. Start analysis within 2 hrs of receipt in lab.	
Oil and Grease	G	1000	G	HCl or $\text{H}_2\text{SO}_4$ to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	28 d	28 d

## General Lab Criteria

<b>Approved Standard Methods</b>	
CBOD / BOD 5 Day	Std Methods 5210-B
Ammonia, Selective Electrode Method	Std Methods 4500-NH3 D
Total Residual Chlorine, DPD Colorimetric Method	Std Methods 4500-Cl G
Total Suspended Solids, Dried at 103-105°C	Std Methods 2540-D
Dissolved Oxygen, Membrane Electrode Method	Std Methods 4500-O G
pH, Electrometric Method	Std Methods 4500-H+ B
Fecal Coliform, Membrane Filter Procedure	Std Methods 9222D
Escherichia Coli, Enzyme Substrate Test	Std Method 9223B
Escherichia Coli Membrane Filtration Procedure	EPA Method 1603
Oil and Grease	USEPA 1664A or Std Methods 5520B
Metals, general	USEPA 200, Std Methods 3111B or C, or 3120B
Volatiles (Purgeables by purge and trap)	USEPA 6210, Std Methods 624
Semi-Volatiles (Base/Neutrals and acids)	USEPA 6410, Std Methods 625
Pesticides	USEPA 6410 and 6630, Std Methods 608