

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 28, 2011

Re: Ross County
Huntington Local Schools
Compliance Evaluation Inspection
NPDES Permit OPT00007*GD
Correspondence (PWW)

Mr. Jerry Mowery, Superintendent
Huntington Local School District
188 Huntsman Road
Chillicothe, Ohio 45601

Dear Mr. Mowery:

On October 4, 2011, I conducted an inspection of the Huntington Local Schools wastewater treatment plant (WWTP). Ron Carroll represented the school and assisted me during the inspection. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPT00007*GD. A copy of the inspection report is attached.

As a part of the inspection, we have reviewed your self-monitoring reports from January 1, 2011 to October 1, 2011 for the Huntington Local Schools WWTP. Our review indicates the plant violated NPDES permit number OPT00007*GD several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	4/14/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	3.94	5/1/2011
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	7.8	5/8/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	17.5	9/1/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	.23	.33119	9/1/2011
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	17.5	9/15/2011
001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	9/21/2011

Please provide a written response to these comments within 30 days upon receipt describing how the above items will be addressed. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure: Compliance Inspection Report

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00007*GD	OH0048607	October 4, 2011	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Huntington Local School District 188 Huntsman Road Chillicothe, Ohio 45601	10:30 a.m.	September 1, 2008
	Exit Time	Permit Expiration Date
	11:06 a.m.	August 31, 2013

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Ron Carroll, Maintenance Supervisor	(740) 663-5892
Name, Address and Title of Responsible Official	Phone Number
Jerry Mowery, Superintendent 188 Huntsman Road Chillicothe, Ohio 45601	(740) 633-5892


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>N/A</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


Please see attached letter.



Jack Knapp, Inspector, Ohio EPA, Southeast District Office

10/27/11

Date



Jennifer M. Witte, Reviewer, Ohio EPA, Southeast District Office

10/28/11

Date