

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 13, 2011

Re: Ross County
Carousel Court MHP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PV00008*FD
Correspondence (PWW)

Mr. Asa Elsea
Elsea, Inc.
P.O. Box 588, 2015 Stone Ridge Drive
Circleville, Ohio 43113

Dear Mr. Elsea:

We have reviewed your self-monitoring reports covering the months of April through June of 2011 for the Carousel Court MHP Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	1D Qty	1.23	1.53293	4/21/2011
001	00530	Total Suspended Solids	30D Qty	0.82	.83081	4/1/2011
001	80082	CBOD 5 day	1D Qty	1.03	1.53293	4/21/2011
001	80082	CBOD 5 day	30D Qty	0.68	.86298	4/1/2011


- * 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response has been sent prior to this letter no further action is required.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,

A handwritten signature in black ink, appearing to read "Jack Knapp", written in a cursive style.

Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Mr. Tom Bouts, Operator, Carousel Court MHP