



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 15, 2008

**Re: Ross County
Country Woods Estates
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PV00025*BD
Correspondence (PWW)**

Mr. John Cook, Owner
Country Woods Estates MHP
2150 Stone Road
Chillicothe, Ohio 45601

Dear Mr. Cook:

We have received your self-monitoring reports covering the months of January through March 2008 for the Country Woods Estates mobile home park. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	3.71	1/1/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	3.71	1/24/2008
001	00530	Total Suspended Solids	30D Conc	12	17.	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	11.5	2/1/2008
001	80082	CBOD 5 day	30D Conc	10	12.	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	11.5	2/26/2008
001	00530	Total Suspended Solids	30D Conc	12	16.	3/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	6.42	3/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0939	.13766	3/1/2008
001	80082	CBOD 5 day	30D Conc	10	11.	3/1/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	6.42	3/21/2008

*1 D Conc is equal to the maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.
30 D Qty is equal to average monthly loading limit.


Country Woods Estates

Page 2

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation to these violations has been sent to our office no response is necessary to this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Operator